





NOTE: SADDLES ON TANK
EQUAL DISTANCE FROM
CENTER OF TANK.

All piping connections
should not restrain tank.

WELDED ROD TO
ACT AS HINGE
(PIVOT POINT)

C.1.101



1150-D Burnett Ave, Concord, CA 94520 USA 1-800-893-6723 US & Canada, Fax: 925-686-6713 www.forceflow.com / info@forceflow.com

HYDRAULIC STATIONARY TANK LOAD CELL SYSTEM with CENTURY INDICATOR (5,000 lb. to 60,000 lb. Capacities)

: HYDSTAT.pdf)

Drawn by: SLP

Date: 09/01/95

Revised: 02/05/99

Drawing Number

vised: 02/05/9

30340

File: T4\O&M\STATHYD\HYDSTATN.tcw (X01.pdf) (WEB: HYDSTAT.pdf)