

TANK LOAD MODE

TANK
LOAD

Allows you to load new tanks without adversely affecting the "AMOUNT USED" and "DAILY USAGE" displays.

It also allows you to enter the tare weight(s) of your tanks if you choose "Manual" tank load mode, or load the net weight of a cylinder if you choose the "Auto" tank load mode. (See Code Setup 9085)

WARNING ! DO NOT UNLOAD or LOAD tanks until "CHANGE TANKS NOW, THEN PRESS ENTER" appears on the display. If you load or unload tanks before reaching this step, the "amount used" and "daily usage" displays will be incorrect.

Digital Display

Action Required - Press "ENTER" after completing each step.

Step 1

NET REMAINING
SCALE 1 = XXXX

Press

TANK
LOAD

to enter the tank load mode.

Step 2

ENTER SCALE #
1 THRU 2 X

Press

1 or

then?

ENTER

Enter the scale NUMBER that you want to load/unload tanks. This "freezes" or "holds" the AMOUNT USED and DAILY USAGE displays until feeding resumes).

Skip to STEP 7 in "FIXED" Tank Applications.

"PORTABLE" Tank Applications (Follow Steps 1 thru 6 only) (such as Ton Containers, Drums and Cylinders)

Step 3

TARE MODE
*AUTO MANUAL



Press

MENU
↑

to select which method, then press

ENTER

Use "MANUAL" for PARTIALLY FULL containers.
...If you chose "MANUAL" you will manually enter tank tare weight in Step 6.

Use "AUTO" for FULL containers.

...If you chose "AUTO" the WIZARD automatically loads the net weight and goes into the weighing mode (skip Step 6).

Step 4

CHANGE TANKS NOW
THEN PRESS ENTER

Remove empty tanks and place new tank(s) onto the scale then press

ENTER

Step 5

WAIT

Wait until this clears to continue.

...If MANUAL chosen above in Step 3...

Step 6

SCALE #2 TANK #1
TARE = XXXX

MANUAL Mode: Requires that you enter tare weight of EACH tank on EACH scale. (Example: Scale #2, tare weight of TANK #1, then TANK #2, etc). After entering the tare weights of all your tanks, the WIZARD 4000 automatically adds them up and subtracts them from the gross weight.

"FIXED" Tank Applications (Follow Steps 1, 2 and 7 only) (such as Chem-Scale, Hoppers, Powercells and Ultrasonic)

Step 7

FILL TANK NOW
THEN PRESS ENTER

Fill your tank with chemicals, then press

ENTER

FORCE FLOW
FLOQUIP

QUESTIONS ? Help Hotline: 1-800-893-6723

W.2.103

1150-D Burnett Ave, Concord, CA 94520 USA
1-800-893-6723 US & Canada, Fax: 925-686-6713
www.forceflow.com / info@forceflow.com

File: T4O&MAWZMSTRWZDAY1B.tcw (B07.pdf) (WEB: B07.pdf)